

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 170

Dated:

It is certified that an inspection team headed by Rajesh Kumar (Asstt. Engineer)

(Name of Officers with designation) from PHD Subdivision Haridwar PHED

inspected the The Gurukul Sr. Sec. School Gurukul Narsan

(Name & Address of the school) on 20/06/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 168/UJS/DLWQTM/202425 dated 24/04/2024

of Mayapur Haridwar (PHED Lab) certified that

the The Gurukul Sr. Sec. School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 20/06/2024 - 19/06/2025

Signature with Seal: [Signature]
Name: Assistant Engineer
Designation: Public Health Department
Name & Address of the Office / Department: Haridwar (U.K.)

To THE CHAIRMAN
THE GURUKUL SR. SEC. SCHOOL
GURUKUL NARSAN, HARIDWAR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jal kal Mayapur, Haridwar**

Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com



TC-12836

TEST REPORT ID : 168/UJS/DLWQTML/2024-25

Dated:24/04/2024

TEST REPORT

Name and Address of Organization/ Customer	The Gurukul Senior Secondary School Gurukul Narsan, Roorkee Haridwar		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample submitted from The Gurukul Senior Secondary School
Reference Sample Identification:	DLWQTML/UJS/2024-26		Date of Start of Analysis:23/04/2024
			Date of End of Analysis:24/04/2024
Date and Time of Sample Received:23/04/24& 16:25 PM	Sample Collected by:	Customer	

SN	Parameters	Results	Desirable Limit (IS 10500:20 12)	Permissible Limit (IS 10500:2012) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.48	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 2022, Electrometric method
2.	Total Dissolved Solids (TDS), mg/L,Max	88	500	2000	IS 3025 (Part 16), 2023 Gravimetric Method
3.	Turbidity, NTU,Max	Less Than 1	1	5	IS 3025 (Part 10), 2023 Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L,Max	60	200	600	IS 3025 (Part 23), 2023 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L,Max	66	200	600	IS 3025 (Part 21), 2009 RA:2019, EDTA Titrimetric Method
6.	Calcium, mg/L,Max	16.8	75	200	IS 3025 (Part 40), 2023, EDTA Titrimetric Method
7.	Magnesium, mg/L,Max	5.832	30	100	APHA 24 th -3500-Mg Method B:2023 (Calculation Method)
8.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2022
9.	Chloride, mg/L, Max	4	250	1000	IS 3025 (Part 32),2019 Argentometric Method
10.	Colour , Hazen	Less Than 1	5	15	IS 3025 (Part 4): 2021Platinum Cobalt (Visual Comparison)

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
- Result apply to the sample as received.
- The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

Checked By

(Er. Rajesh Chauhan)

Technical Manager

District Water Quality Testing Monitoring
Laboratory
Uttarakhand Jal Sansthan, Haridwar

Review and Authorized By

(Er. Anjali Palariya)

Authorized signatory,
District Water Quality Testing Monitoring
Laboratory ,
Uttarakhand Jal Sansthan, Haridwar

Digitally signed by Balesh
Date: 2024.04.30 11:36:35 +05:30
Reason: reason
Location: location

End of Report



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jal kal Mayapur, Haridwar
Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com

TEST REPORT ID: 168/UJS/DLWQTML/2024-25

Dated: 24/04/2024

TEST REPORT

Name and Address of Organization/ Customer	The Gurukul Senior Secondary School Gurukul Narsan, Roorkee Haridwar		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample submitted from The Gurukul Senior Secondary School
Reference Sample Identification:	DLWQTML/UJS/2024 -26		Date of Start of Analysis:23/04/2024
Date and Time of Sample Received:23/04/24& 16:25 PM	Sample Collected by:	Customer	
			Date of End of Analysis:24/04/2024

SN	Parameters	Results	Desirable Limit (IS 10500:20 12)	Permissible Limit (IS 10500:2012) in the Absence of alternative source	Std. Test Method
1.	Residual Free Chlorine, mg/L, Min	Not Detected	0.2	1.0	APHA 23rd Ed.-4500- CI-G
2.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 32): 1988
Bacteriological Parameters					
3.	Total Coliform, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B
4.	<i>E. coli</i> , MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
- Result apply to the sample as received.
- The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

Checked By

(A) Anil

(Er. Rajesh Chauhan)

Technical Manager
District Water Quality Testing Monitoring
Laboratory
Uttarakhand Jal Sansthan, Haridwar

Review and Authorized By

Anil

(Er. Anjali Palariya)
Authorized Signatory,
District Water Quality Testing Monitoring
Laboratory,
Uttarakhand Jal Sansthan, Haridwar

Anil
Principal

The Gurukul Senior Secondary School
Gurukul Narsan, Haridwar (U.K.)

Anil

Manager

The Gurukul Sr. Sec. School
Gurukul Narsan, Haridwar (U.K.)